



2019 Poland Spring® Origin Water Analysis Report

Parameter	Reporting Limit	FDA SOQ / EPA MCL	Poland Spring® Origin Water
Primary Inorganics			
Antimony	0.001	0.006	ND
Arsenic	0.002	0.01	ND
Asbestos (MFL)	0.2	7	ND
Barium	0.1	2	ND
Beryllium	0.001	0.004	ND
Cadmium	0.001	0.005	ND
Chromium	0.005	0.1	ND
Cyanide	0.1	0.2	ND
Fluoride	0.1	2.0 (1.4 – 2.4)	ND
Lead	0.002	0.005	ND
Mercury	0.001	0.002	ND
Nickel	0.01	0.1	ND
Nitrate as N	0.4	10	ND
Nitrite as N	0.4	1	ND
Selenium	0.005	0.05	ND
Thallium	0.001	0.002	ND
Secondary Inorganics			
Alkalinity, Total as CaCO ₃	2	NR	15
Aluminum ♦	0.05	0.2	ND
Boron	0.1	-	ND
Bromide	0.005		ND
Calcium	1	NR	4.8
Chloride ♦	1	250	ND
Copper	0.05	1	ND
Iron ♦	0.1	0.3	ND
Magnesium	0.5	NR	1.3
Manganese ♦	0.02	0.05	ND
pH (pH Units) ♦		6.5 – 8.5	7.2
Potassium	1	NR	ND
Silver ♦	0.01	0.1	ND
Sodium	1	NR	1.6
Specific Conductance @ 25C (umhos/cm)	2	NR	43
Sulfate ♦	0.5	250	3.8
Total Dissolved Solids ♦	10	500	32
Total Hardness (as CaCO ₃)	3	NR	17
Zinc ♦	0.05	5	ND



2019 Poland Spring® Origin Water Analysis Report

Parameter	Reporting Limit	FDA SOQ / EPA MCL	Poland Spring® Origin Water
Physical			
Apparent Color (ACU) ♦	3	15	ND
Odor at 60 C (TON) ♦	1	3	ND
Turbidity (NTU)	0.1	5	ND
Microbiologicals			
Total Coliforms (Cfu/100 mL)	1	Absent	ND
Radiologicals			
Gross Alpha (pCi/L)	3	15	ND
Gross Beta (pCi/L)	4	50.00†	ND
Radium-226 + Radium-228 (sum) (pCi/L)		5	ND
Uranium	0.001	0.03	ND
Volatile Organic Compounds			
1,1,1-Trichloroethane (1,1,1-TCA)	0.0005	0.2	ND
1,1,2,2-Tetrachloroethane	0.0005	0.001†	ND
1,1,2-Trichloroethane (1,1,2-TCA)	0.0005	0.005	ND
1,1,2-Trichlorotrifluoroethane	0.01	1.200†	ND
1,1-Dichloroethane (1,1-DCA)	0.0005	0.005†	ND
1,1-Dichloroethylene	0.0005	0.007	ND
1,2,4-Trichlorobenzene	0.0005	0.07	ND
1,2-Dichlorobenzene (o-DCB)	0.0005	0.6	ND
1,2-Dichloroethane (1,2-DCA)	0.0005	0.005	ND
1,2-Dichloropropane	0.0005	0.005	ND
1,4-dichlorobenzene (p-DCB)	0.0005	0.075	ND
Benzene	0.0005	0.005	ND
Carbon tetrachloride	0.0005	0.005	ND
Chlorobenzene (Monochlorobenzene)	0.0005	0.1	ND
cis-1,2-Dichloroethylene	0.0005	0.07	ND
Ethylbenzene	0.0005	0.7	ND
Methylene Chloride (Dichloromethane)	0.0005	0.005	ND
Methyl-tert-Butyl-ether (MTBE)	0.003	0.013†	ND
Styrene	0.0005	0.1	ND
Tetrachloroethylene	0.0005	0.005	ND
Toluene	0.0005	1	ND
trans-1,2-Dichloroethylene	0.0005	0.1	ND
trans-1,3-Dichloropropene (Telone II)	0.0005	0.0005†	ND
Trichloroethene (TCE)	0.0005	0.005	ND
Trichlorofluoromethane (Freon 11)	0.005	0.150†	ND



2019 Poland Spring® Origin Water Analysis Report

Parameter	Reporting Limit	FDA SOQ / EPA MCL	Poland Spring® Origin Water
Vinyl chloride (VC)	0.0005	0.002	ND
Xylene (Total)	0.001	10	ND
Chlorinated Acid Herbicides			
2,4,5-TP (Silvex)	0.001	0.05	ND
2,4-Dichlorophenoxyacetic acid(2,4-D)	0.01	0.07	ND
Bentazon	0.002	0.018†	ND
Dalapon	0.01	0.2	ND
Dinoseb	0.002	0.007	ND
Pentachlorophenol	0.0002	0.001	ND
Picloram	0.001	0.5	ND
Chlorinated Pesticides			
Alachlor	0.001	0.002	ND
Chlordane	0.0001	0.002	ND
Endrin	0.0001	0.002	ND
Heptachlor	0.00001	0.0004	ND
Heptachlor epoxide	0.00001	0.0002	ND
Lindane	0.0002	0.0002	ND
Methoxychlor	0.01	0.04	ND
Polychlorinated biphenyls (PCBs)	0.0005	0.0005	ND
Toxaphene	0.001	0.003	ND
Miscellaneous Herbicides			
2,3,7,8-TCDD (DIOXIN)	0.000000005	0.00000003	ND
Diquat	0.004	0.02	ND
Endothall	0.045	0.1	ND
Glyphosate	0.025	0.7	ND
Semi-Volatile Organic Compounds (Acid/Base/Neutral extractables)			
Atrazine	0.0005	0.003	ND
Benzo(a)pyrene	0.00001	0.0002	ND
bis(2-Ethylhexyl)phthalate	0.003	0.006	ND
Di(2-ethylhexyl)adipate	0.005	0.4	ND
Hexachlorobenzene	0.0005	0.001	ND
Hexachlorocyclopentadiene	0.001	0.05	ND
Molinate	0.002	0.020†	ND
Simazine	0.001	0.004	ND
Thiobencarb	0.001	0.070†	ND



2019 Poland Spring® Origin Water Analysis Report

Parameter	Reporting Limit	FDA SOQ / EPA MCL	Poland Spring® Origin Water
Carbamates (Pesticides)			
Aldicarb	0.001	0.003	ND
Aldicarb sulfone	0.001	0.002	ND
Aldicarb sulfoxide	0.001	0.004	ND
Carbofuran	0.005	0.04	ND
Oxamyl	0.02	0.2	ND
Microextractables			
1,2-Dibromo-3-chloropropane	0.00001	0.0002	ND
1,2-Dibromoethane (EDB)	0.00002	0.00005	ND
Disinfection Byproducts			
Bromate	0.001	0.01	ND
Chlorite	0.02	1	ND
D/DBP Haloacetic Acids (HAA5)	0.002	0.06	ND
Total Trihalomethanes (Calc.)	0.001	0.08	ND
Residual Disinfectants			
Chloramines	0.1	4	ND
Chlorine Dioxide	0.24	0.8	ND
Chlorine Residual, Total	0.1	4	ND
Other Contaminants			
Perchlorate	0.002	0.002	ND



2019 Poland Spring® Origin Water Analysis Report

Parameter	Reporting Limit	Poland Spring® Origin Water
Perfluorinated Compounds (PFC)		
11-chloroeicosafluoro-3-oxaundecane-sulfonic acid	0.00001	ND
4,8-dioxa-3H-perfluorononanoic acid (ADONA)	0.00001	ND
9-chlorohexadecafluoro-3-oxanone-sulfonic acid	0.00001	ND
Hexafluoropropylene oxide dimer acid (HFPO-DA)	0.00001	ND
N-ethyl Perfluorooctanesulfonamidoacetic acid	0.00001	ND
N-methyl Perfluorooctanesulfonamidoacetic acid	0.00001	ND
Perfluorobutanesulfonic acid (PFBS)	0.00001	ND
Perfluorodecanoic acid (PFDA)	0.00001	ND
Perfluorododecanoic acid (PFDoA)	0.00001	ND
Perfluoroheptanoic acid (PFHpA)	0.00001	ND
Perfluorohexanesulfonic acid (PFHxS)	0.00001	ND
Perfluorohexanoic acid (PFHxA)	0.00001	ND
Perfluorononanoic acid (PFNA)	0.00001	ND
Perfluorooctanesulfonic acid (PFOS)	0.00001	ND
Perfluorooctanoic acid (PFOA)	0.00001	ND
Perfluorotetradecanoic acid (PFTA)	0.00001	ND
Perfluorotridecanoic acid (PFTrDA)	0.00001	ND
Perfluoroundecanoic acid (PFUnA)	0.00001	ND

All units in (mg/l) or Parts per Million (PPM) unless otherwise indicated.

◆ EPA Secondary Standard - non-enforceable guidelines regulating contaminants that may cause cosmetic or aesthetic effects in drinking water.

† Set by California Dept. of Health Services

MRL - Minimum Reporting Limit: Where available, MRLs reflect the Method Detection Limits (MDLs) set by the U.S. Environmental Protection Agency or the Detection Limits for Purposes of Reporting (DLRs) set by the California Department of Health Services. These values are set by the agencies to reflect the minimum concentration of each substance that can be reliably quantified by applicable testing methods, and are also the minimum reporting thresholds applicable to the Consumer Confidence Reports produced by tap water suppliers.

EPA MCL - Maximum Contaminant Level: The highest level of a substance allowed by law in drinking water (bottled or tap water). The MCLs shown are the federal MCLs set by the U.S. Environmental Protection Agency and the Food and Drug Administration, unless no federal MCL exists. †Where no federal MCL exists, the MCLs shown are the California MCLs set by the California Department of Health Services. California MCLs are identified with an (†).

Primary Drinking Water Standard (PSWS): Legally enforceable primary standard and treatment techniques that apply to public water systems, which protect health by limiting the levels of contaminants in drinking water.

Public Health Goals (PHG's): Concentrations of drinking water contaminants that pose no significant health risk if consumed for a lifetime, based on current risk assessment principles, practices and methods.

FDA SOQ - Standard of Quality: The standard of quality for bottled water is the highest level of a contaminant that is allowed in a container of bottled water, as established by the United States Food and Drug Administration (FDA) and the California Department of Public Health. The standards can be no less protective of public health than the standards for public drinking water, established by the U.S. Environmental Protection Agency (EPA) or the California Department of Public Health.

Reported Results - The highest level of each substance detected at or above the MRL in representative finished product samples.



2019 Poland Spring® Origin Water Analysis Report

NA - Not applicable to specific test method or test parameter

PPB - Parts per Billion. Equivalent to micrograms per liter ($\mu\text{g/l}$).

MFL - Million Fibers per Liter.

Poland Spring® Origin Sources: White Cedar Spring, Dallas Plt., ME

Factory Water Treatment Process for Poland Spring® Natural Spring Water

The final treatment consists of the following process

Spring Water
1. Storage Silo holding filtered source water
2. Microfiltration
3. Ultraviolet and/ or Ozone disinfection
4. Bottling

Statements Required Under California Law

"Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the United States Food and Drug Administration, Food and Cosmetic Hotline (1-888-723-3366)."

"In order to ensure that bottled water is safe to drink, the United States Food and Drug Administration and the State Department of Public Health prescribe regulations that limit the amount of certain contaminants in water provided by bottled water companies."

"Some persons may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons, including, but not limited to, persons with cancer who are undergoing chemotherapy, persons who have undergone organ transplants, persons with HIV/AIDS or other immune system disorders, some elderly persons, and infants can be particularly at risk from infections. These persons should seek advice about drinking water from their health care providers. The United States Environmental Protection Agency and the Centers for Disease Control and Prevention guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791)."

"The sources of bottled water include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water naturally travels over the surface of the land or through the ground, it can pick up naturally occurring substances as well as substances that are present due to animal and human activity. Substances that may be present in the source water include any of the following:

1. Inorganic substances, including, but not limited to, salts and metals, that can be naturally occurring or result from farming, urban storm water runoff, industrial or domestic wastewater discharges, or oil and gas production.
2. Pesticides and herbicides that may come from a variety of sources, including, but not limited to, agriculture, urban storm water runoff, and residential uses.
3. Organic substances that are byproducts of industrial processes and petroleum production and can also come from gas stations, urban storm water runoff, agricultural application, and septic systems.
4. Microbial organisms that may come from wildlife, agricultural livestock operations, sewage treatment plants, and septic systems.
5. Substances with radioactive properties that can be naturally occurring or be the result of oil and gas production and mining activities."

FDA website for recalls: <https://www.fda.gov/Safety/Recalls/default.htm>